

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



Water sample collected from "R.P Memorial Public School" K-03 Mohan Garden , Uttam Nagar New Delhi -110059 vide challan No- 268 Dated- 22.12.2022.

| S. No | Parameter | Units | Limit | | S1 |
|------------------------------------|------------------------------|--------|-------------------|-------------|------------|
| | | | Acceptable | Permissible | |
| PHYSICAL EXAMINATION | | | | | |
| 1. | Date of collection | ----- | -- | -- | 07.01.2023 |
| 2. | Date of Analysis | ----- | -- | -- | 09.01.2023 |
| 3. | Colour | Hazen | 5.0 | 15 | Clear |
| 4. | Odour | ----- | No. Objectionable | | No Obj |
| 5. | Turbidity | N.T.U. | 1.0 | 5.0 | 0.98 |
| 6. | PH value | ----- | 6.5 | 8.5 | 7.0 |
| 7. | Electrical Conductivity | µmho | -- | -- | 374.6 |
| 8. | Total dissolved solids | mg/l | 500 | 2000 | 243.1 |
| CHEMICAL EXAMINATION | | | | | |
| 9. | P th Alkalinity | mg/l | -- | -- | NIL |
| 10. | Total Alkalinity | mg/l | 200 | 600 | 110 |
| 11. | Total Hardness | mg/l | 200 | 600 | 128 |
| 12. | Calcium Hardness | mg/l | -- | -- | 90 |
| 13. | Magnesium Hardness | mg/l | -- | -- | 38 |
| 14. | Calcium as Ca | mg/l | 75 | 200 | 36 |
| 15. | Magnesium as Mg | mg/l | 30 | 100 | 9.12 |
| 16. | Ammonia as N | mg/l | 0.5 | N.R. | NIL |
| 17. | Nitrite as N | mg/l | --- | -- | NIL |
| 18. | Nitrate as NO ₃ | mg/l | 45 | N.R. | 3.0 |
| 19. | Sulphate | mg/l | 200 | 400 | 28 |
| 20. | Chloride | mg/l | 250 | 1000 | 48 |
| 21. | Dissolved Iron | mg/l | 0.3 | N.R. | 0.04 |
| 22. | Fluoride | mg/l | 1 | 1.5 | 0.08 |
| 23. | Cyanide | mg/l | 0.05 | N.R. | ND |
| 24. | Residual Chlorine | mg/l | 0.20 | 1.0 | NIL |
| BACTERIOLOGICAL EXAMINATION | | | | | |
| 25. | Coli-form per 100 ml at 37°C | MPN | 0 | | 0 |

REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.

S. Pandey
Chemist
R.P.M.
Manager
R.P. Memorial Public School
K-3, Mohan Garden
Uttam Nagar, New Delhi-59

Prad
HOS/Vice Principal
R.P. MEMORIAL PUBLIC SCHOOL
(Recognised)
K-3, Mohan Garden
Uttam Nagar, New Delhi-110059

Jalbir
12/01/23
ACWA
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works, Nangloi, Delhi-110041



B. 8

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT - WEST ZONE
RAJOURI GARDEN, NEW DELHI 110027

No. D-SC/55 /HD/WZ/2022

Dated 21/12/2022

SCHOOL HEALTH CERTIFICATE

1 Name of the School : R.P. MEMORIAL PUBLIC SCHOOL

2 School Address: K-3 MOHAN GARDEN, UTTAM NAGAR, NEW DELHI 110059.

3 No. of Shifts : One Timings 08:20 AM TO 02:00 PM

4 No. of Students: Boys: 881 Girls 571 Total 1452

5 No. of Staffs: Male 15 Female 55 Total 70


ACCOMODATIN PROVIDED IN THE SCHOOL

- Floor area/ space in the Classroom is sufficient
- Classes are well lighted
- Classrooms are well ventilated
- Classes are kept neat and clean
- Classrooms/Building is well white washed
- Drinking water is wholesome as per water test report.
- The Toilet arrangements for students and staff are in sanitary & hygiene from health point of view sufficient in number.
- The over sanitary condition of school is found satisfactory from health point of view and valid upto one year from the date of issuance.


REMARKS - This certificate does not indicate permissibility from land point of view and if Building Department or any other Govt agency takes actions against u/constructions or any dispute then the Health Certificate will be stand cancelled / revoked without any further notice continuation in this regard This certificate is valid for one year from the date of issuance

R.P. MEMORIAL PUBLIC SCHOOL
K-3 MOHAN GARDEN, UTTAM NAGAR
NEW DELHI 110059


Manager
R.P. Memorial Public School
K-3, Mohan Garden
Uttam Nagar, New Delhi-59


Dy. Health Officer
West Zone

Dr. V. N. Bhargava
DHO West Zone


HOS Vice Principal
R.P. MEMORIAL PUBLIC SCHOOL
(Recognised)
K-3, Mohan Garden
Uttam Nagar New Delhi-110059